

**Consultation Response from KC,
Lead Local Flood Authority**

2025/93480 Land off Parkwood Road/Weavers Lane, Longwood, Huddersfield, HD3 4TT

Erection of 28 dwellings with associated landscaping and external works

Date Responded: 24/03/2026.

Responding Officer: Martin Stephenson

Responding Ref: 1

Documents reviewed by the LLFA:

Lynas Engineers:

- 25016-LE-ZZ-05-RP-D-0001 Flood Risk Assessment and Drainage Strategy, Rev P01 dated 09/01/2026.
- 25016-LE-ZZ-05-RP-D-0002, Drainage Technical Note, Rev P01 dated 17/12/2025.

Drainage Summary:

(1) Gradients within the site are greater than 1 in 10, therefore infiltration into the ground is not viable due to the risk of re-emergence. The LLFA accepts the proposal to discharge attenuated surface water run-off to the Yorkshire Water Surface Water sewer leading to Stoney Lane at a design discharge rate of 3.5l/s and to provide sufficient attenuation storage for the critical 1 in 100 year rainfall (plus Climate Change) without flooding off-site.

(2) The LLFA confirms acceptance of the following:

- Exceedance flood routing
- Hydraulic Calculations
- Proposed Maintenance Strategy

(3) The proposals outlined in the Drainage Technical Note (including the proposed Drainage GA plan) are generally accepted, however the LLFA has the following comments:

- Construction Phase temporary drainage – flowrate off-site during the 1 in 2 year rainfall event is to be limited to 2.5l/s.
- Details of the Debris Screen on the watercourse have not been provided and will require LLFA approval prior to installation.
- Confirmation whether the surface water drainage system is to be offered for adoption by Yorkshire Water is required.

Kirklees Flood Management and Drainage as Lead Local Flood Authority requires further information as detailed in (3) above are provided