

Consultation Response from KC,  
Lead Local Flood Authority

2025/93532 Bromley Farm Quarry, Barnsley Road, Upper Cumberworth, Huddersfield, HD8 8PD

Discharge of details reserved by conditions 6 (site preparation and clearance), 8 (BEMP), 9 (landscaping), 11 (fencing), 12 (WSI), 14 (shared access), 16 (access road), 19 (wheel bath), 22 (Access Management Plan), 23 (parking), 49 (surface water discharge), 59 (delivery HGV route) on previous permission 2023/91280 for quarrying operations for the extraction of clay, shale and incidental coal and subsequent restoration by means of importation of inert wastes

Date Responded: 13/01/2026.

Responding Officer: Martin Stephenson

Responding Ref: 1

### Discharge of Drainage Conditions

- No. 49 (surface water discharge)

### Documents reviewed by the LLFA:

Silkstone Environmental Ltd.:

- 261/01/bfq/swms/1125, Surface Water Management Scheme, Rev 1 dated 05/11/2025.

### Drainage Summary:

#### Condition 49:

The submitted Surface Water Management Scheme, Section 1.2 refers to Condition 50, however the document appears to be in relation to Condition 49. Discharge of Condition 50 (Flood Risk Assessment and Hydrogeological Risk Assessment) is not requested in this application and therefore would require a separate one.

The LLFA confirms that the surface water drainage proposals set out in Section 3.3 and proposed maximum discharge rate of **25l/s** to the Water Treatment Area (outfalling to East Hill Beck) set out in Section 3.160 are accepted together with the management and maintenance proposals in Section 5.

Therefore, Condition 49 **can be** discharged.