

Our Ref: 2025 / 202 / df

31<sup>st</sup> March 2026

FAO: Dan Heneghan  
Heneghan Architecture



Dear Dan,

### **Review of Existing Highway Retaining Wall Construction**

In response to highways comments, with regards to the existing retaining structure, it would be our intention to leave the existing in position, to avoid additional excavation and potential destabilisation of the existing road, in front of the wall we can adopt the detail provided with the terraced subgrade level and compacted hardcore layers in between the rear of the proposed retaining wall and the existing retaining wall.

I trust the above meets your present requirements, should you have any queries with regard to the above, please do not hesitate to contact me.

For and on behalf of SGM Structural Design:

A handwritten signature in black ink, appearing to read 'D Ford', is written over the typed name.

**Darren Ford**  
*MEng (Hons)*  
Director  
**SGM Structural Design Ltd**