




K

E

Y

S104 Storm water manhole

S104 Foul water manhole

S104 Storm water sewer

S104 Foul water sewer

Combined sewer

Gully

Yard gully

Channel Drain

(min B125 grade cover)

N

N

O

T

E

S

ATTENTION IS DRAWN TO THE REQUIREMENTS OF THE CONSTRUCTION DESIGN AND MANAGEMENT REGULATIONS 2015 AND THE DUTIES AND RESPONSIBILITIES CONTAINED THEREIN.

ALL DESIGNS ARE SUBJECT TO THE APPROVAL OF ALL RELEVANT AUTHORITIES

- For longitudinal sections refer to drawing 425/92/06
- No services are to be sited directly over, or within 1m of, an adoptable sewer or manhole.
- Private drainage connections to adoptable sewers to be via 45° junction.
- Off site manholes already built must have invert levels checked prior to connection to the off site drainage
- Any connections to existing sewers/manholes are to be supervised by Yorkshire Water.
- All connections to proposed public sewers to be minimum 150mmØ.
- Any land drain or water course on site to be diverted as not to pass under proposed buildings. Diversion to be approved and inspected on site by the Local Authority.

Adoption General Notes

- All adoptable sewer works and materials to be in accordance with Sewerage Sector Guidance (SSG), the relevant British/European and the adopting Water Authority standards/Requirements/Addendum to the Mechanical and Electrical Specification and Kitemarked.
- Manhole covers shall/must have a clear opening of 600mm and shall be Class D400 to BS EN 124 with 150mm deep frames in highways.
- Filled ground must be filled and consolidated under the supervision, and to the satisfaction, of INWL before any sewer works are carried out.
- Cover slabs must carry the BS1 Kitemark or may be rejected by INWL inspector. Where the clear opening of the Kitemarked product is different to that of the cover and frame, a loading bearing slab should be fitted above the cover slab to bring the size down to 600x600mm for INWL specified cover size. Please refer to the Concrete Pipe Systems Association (CPSA), 'Technical Bulletin' issued autumn 2004 for kitemarked cover slab opening sizes.
- The adoptable sewers should be a minimum of 1m and manholes 0.5m from kerb faces and service margins.
- Sewers must have 5 metres clearance from trees and hedges, (please also refer to Figure 2.3 on page 33 in 'Sewers for Adoption' 6th Edition for restrictions on tree planting adjacent to Sewers).
- Sewers to be laid in Class 'S' bedding (150mm granular bed and surround). Where depth of cover to top of the sewer is less than 1.2m in highways and verges (or less than 900mm in none vehicular access areas) then a concrete slab should be provided above the granular bed and surround.
- Bedding and backfill material to conform to the requirement of Water Industry Specification 4-08-02 (Table A2)
- Adoptable plastic sewer pipes to be BS1 Kitemarked (Certified to WIS 4-35-01 and BS EN13476). Adoptable sewer pipes to be laid in maximum 3 metre lengths unless there is a specific operational need to lay longer.
- Plastic channel sections in manholes are not acceptable and clayware is preferable. Plastic channels are difficult to set in concrete and a satisfactory finish cannot be obtained on the benching.
- The chamber size of manholes with more than one connection in them may need to be increased on an increment to accommodate the connections and bends.
- INWL's policy is not generally to accept Type 'C' brick manhole and 1050mm dia manhole rings. Instead it is preferred that you use a type 'B' manhole with 1200mm dia or 1500mm dia rings, with the opening sited over the channel where depth of cover to pipe soffit is 1-1.5m.
- If plastic pipes are to be used then the following should apply:-
  - All adoptable sewers to be BS1 Kitemark (certified to WIS 4-35-01).
  - Bedding and backfill material to conform to the requirements of Water Industry Specification 4-08-02 (Table A2)
- Where plastic pipes are proposed for adoptable sewers, structural calculations for the plastic pipes and a site investigation report to prove that the ground condition is suitable for the plastic pipes are to be produced.
- Where plastic pipes are installed into the ground prior to getting full technical approval, the developer must provide a CCTV survey of the prospectively adoptable sewers and a deformation test (Light-Line test) of the plastic pipes.
- Demarcation chambers to be a min. 450mmØ chamber for 100mmØ foul & 150mmØ surface water pipes up to 1.2m deep. For depths greater than 1.2m, restricted access opening to 350mm is required for safety reasons.
- Maximum depth of demarcation chamber to be 3m, where depth exceeds 3m, manhole to be constructed as type B manhole.
- Where a B125 cover and frame has been approved, this must not be coated in plastic and must have lifting eyes suitably sized to accommodate standard lifting keys. Screw down covers are not acceptable.
- INWL is not obliged to accept filter drain/land drainage runoff into the public sewer network or adoptable drainage system (directly or in-directly). An alternative method of disposal of the land drainage runoff will therefore be required and you will have to liaise with the Land Drainage Authority/Land Drainage Section with regard to the disposal of the filter drain/land drainage runoff is required.
- Sulphate resisting cement (C20-UC2) and precast concrete products must be used or a laboratory report provided proving that such precautions are not necessary.
- Strength of vitrified clay pipes (if used) to be 40KN/m for 100Ø, 40KN/m for 150Ø, 45KN/m for 225Ø and 72KN/m for 300Ø. All concrete pipes to be Class 120 concrete to EN 1916/BS 5911-1:2002.
- All levels of existing drainage to be confirmed prior to work commencing on site.
- The contractor must allow for any fee's required for road and sewer opening permits, sewer connections and make the appropriate applications.
- There should be enough clearance to accommodate the bedding for both pipes, approx 300mm; If crossover is near rocker then the clearance needed may be increased.

|     |     |          |                                                     |     |
|-----|-----|----------|-----------------------------------------------------|-----|
| F   | MI  | 18.11.25 | Minor revisions to cover & invert levels S19A added | MI  |
| E   | MI  | 10.10.25 | Amended to client comments and general updates      | MI  |
| D   | MI  | 29.08.25 | Amended to suit revised road levels                 | MI  |
| C   | MI  | 29.08.25 | Amended to suit planning layout Rev 008L            | MI  |
| B   | MI  | 30.04.25 | Amended to INWL comments and general updates        | MI  |
| A   | DJG | 04.04.25 | Revised to suit new layout                          | MI  |
| /   | JC  | 26.02.25 | Issued for approval                                 | MI  |
| Rev | By  | Date     | Revision                                            | Chk |

ARP

ARP ASSOCIATES  
Chartered Consulting Engineers

Northwest House • 5 & 6 Northwest Business Park • Servia Hill, Leeds. • L5E 2QH  
☎ 0113 245 8498 ☎ 0113 244 3864 • Leeds@arpassociates.co.uk • www.arpassociates.co.uk  
ARP Associates is a trading division of ARP Geotechnical Ltd, a company registered in England and Wales with company number 3773831, whose registered office is at 5/6 Northwest Business Park, Servia Hill, Leeds LS6 2QH

TITLE

SECTION 104 LAYOUT  
SHEET 2 OF 4

PROJECT

BLACKMOORFOOT ROAD,  
HUDDERSFIELD

CLIENT

MILLER HOMES  
YORKSHIRE

DRAWING STATUS

PRELIMINARY

Scale

1:500 @ A1

Date

FEB 25

Drawn

DJG

Chk.

MI

Drg. No.

0425/92/03.02

Rev

F