

**Consultation Response from KC,  
PROW (Footpaths)**

**2026/90205 Birkenshaw Liberal Club, 10, Croft Street, Birkenshaw, BD11 2HT**

**Discharge of details reserved by conditions 16 (LMMP), 17 (cycle storage), 18 (pedestrian link), 20 (surface water strategy), 28 (retaining walls), 29 (highway drainage structure), 30 (temporary drainage) on previous permission 2024/91853 for erection of 21 dwellings with garages, formation of adoptable road, private road and parking spaces and new car park and beer garden for the Liberal Club**

**Date Responded: 17/02/2026**

**Responding Officer: Mark Drydale, Definitive Map Officer**

**Responding Ref:**

PROW has liaised with the applicant with regard to condition 18 (pedestrian link) and agreed suitable gradients, surfacing, width, and handrail to an agreed specification.

Condition 18 can be discharged.

As a note. The annotated width to the 'Typical Section Through No Dig Footpath' on '[Plan General Ijd 1122876](#)' states: "2000 (Varies to suit layout)". The width must not be less than 2 metres.