

Consultation Response from: KC Environmental Health (Pollution & Noise Control)

2026/90499 - 21, Birchwood Close, Lindley, Huddersfield, HD3 3GZ

Installation of air source heat pump to rear elevation

Date Responded:

Monday, 29 June 2026

Responding Officer:

HK

Responding Ref:

WK202620535

Thank you for consulting Environmental Health on the above application.

COMMENTS

NOISE

The applicant has submitted an unreferenced Noise Impact Assessment, dated 25th of June 2026, prepared by Anita Pullmanova in support of the application. The report identifies that the predicted external Rating Noise Level (L_{Ar,Tr}) at the neighbouring assessment positions 19 and 23 Birchwood Close is 38 dB(A) and 41 dB(A) respectively.

Environmental Health confirm we are satisfied that the proposed installation of the Cosy 6 Air Source Heat Pump will be acceptable, based on a noise level of 41dB (A) at the nearest noise sensitive receptor.