



THIS FORM IS FOR USE BY ELECTRICITY NETWORK OPERATORS TO ADVISE LOCAL PLANNING AUTHORITIES OF PROPOSED WORKS TO BE UNDERTAKEN WITHIN THEIR DESIGNATED AREA THAT ARE CONSIDERED TO BE EXEMPTED UNDER THE OVERHEAD LINES(EXEMPTION)(ENGLAND AND WALES) REGULATIONS 2009. LOCAL AUTHORITIES HAVE THE RIGHT TO INVOKE THE FULL SECTION 37 PROCESS UNDER THE ELECTRICITY ACT 1989 SHOULD IT BE CONSIDERED NECESSARY.

The Form should be sent in triplicate to each Local Planning Authority in whose area the proposed development would be situated.

DETAILS OF APPLICANT

Name: NORTHERN POWERGRID (YORKSHIRE) PLC
Contact person: Colin Wolfe
Address: Chessingham Park
Common Road
Dunnington
York
YO19 5PD

Email: colin.wolfe@northernpowergrid.com

Applicant's reference: CJW/Y012948

Date: 13 April 2026

**To: Kirklees Metropolitan Council
PO Box 1720
Huddersfield
HD1 9EL**

Electricity Act 1989: Overhead Lines (Exemption) (England and Wales) Regulations 2009

It is proposed to undertake the following work that is considered to be exempt from the Electricity Act 1989 by falling within the Overhead Lines (Exemption) (England and Wales) Regulations 2009:

Electricity equipment reinforcements – Land east of Thick Hollins Road, Holmfirth, HD9 3XD

In order to safeguard and improve the electricity supplies in the above area, Northern Powergrid proposes to replace existing open wire low-voltage conductors with aerial bunched conductor on the sections of overhead electric line shown in red on the attached plan.

I attach photographs (from a different location) showing an example of what open wire conductor looks like when upgraded to aerial bunch conductor.

As the new conductor will be a replacement of the existing conductor, the work falls under the exemption detailed in regulation 3(1)(e) of the Overhead Lines (Exemption) (England and Wales) Regulations 2009. The work falls within the limitations in regulation 4 and is not affected by the further restrictions detailed in regulation 5. The electric line affected is not within a European site or an SSSI (as defined in the regulations).

The Council/Authority is requested to indicate that it has no objection to the work being carried out by returning two copies of this Form with the Certificate completed and signed.

Yours faithfully

REDACTED

For and on behalf of the Applicant

Applicant's ref:	Y012948	Location/scheme:	Alma Farm 2151 LV OHL rebuild ABC
------------------	---------	------------------	-----------------------------------