

Consultation Response from: KC Environmental Health (Pollution & Noise Control)**2026/91168 72 Northgate, Huddersfield, HD1 6AE**

Discharge of details reserved by condition 17 (Verification Report) on previous permission 2024/92246 for redevelopment of existing site including demolition of existing car sales room (sui generis) and erection of new 2 storey police station (sui generis) with associated car parking, landscaping and infrastructure

Responding Date:
2nd June 2026**Responding Officer:**
SR**Responding Ref:**
WK202613347**Comments**

In support of the discharge of condition 17 an interim Verification Report by BWB ref: WYP-BWB-XX-XX-T-G-0007_VR, dated May 2026 has been submitted. Whilst we welcome the information provided within the report, by its own admission it informs in section 3.4 that soft landscaping, including a capping layer, is still ongoing with an expected completion of June 2026. Section 5.4 informs BWB have not yet seen a copy of the Environmental Permit of each source of imported material.

Until a final document has been provided clearly demonstrating completion of necessary remediation works and full verification by the consultant we are unable to recommend discharge of condition 17.