

Sent: 15 June 2026 15:29

Subject: RE: Attached letter from Kirklees Council regarding application number 2026/91614 at location Land off, Bankfield Drive, Holmbridge, Holmfirth, HD9 2PH

Further to the DOC application submitted in connection with the above, I would like to advise that condition 17 (retaining walls) cannot be discharged pending the satisfactory conclusion of the technical approval of the design of the new retaining wall abutting Dobb Top Road.

In addition, there are other retaining walls along the PROW and the new public access route whose design has yet to be approved.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

☎ **External:** 01484 221000 **Internal:** 74199

Mobile: None

✉ **Email:** farhad.khatibi@kirklees.gov.uk

