

Sent: 25 June 2026 18:23

Subject: RE: Attached letter from Kirklees Council regarding application number 2026/91685 at location Clough Farm, Long Lane, Earlsheaton, Dewsbury, WF12 8LQ

Further to the DOC application submitted in connection with the above, I would like to advise that condition 10 (highway drainage structures) can not be discharged as the size of manholes located in the highway exceed 1.8m internal diameter and as such non-compliant with our policy and furthermore, the design of attenuation system located in the highway will be liable to a formal technical approval for which a fee of £382.00 (Cat 0 Structures) will be applicable.

Regards

Farhad Khatibi

Bridges & Structures Manager
Structures Section
Highways and Streetscene
Kirklees Council

Highways and Streetscene | Highways Structures | Civic Centre 1 | High Street | Huddersfield | HD1 2NF

☎ **External:** 01484 221000 **Internal:** 74199

Mobile: None

✉ **Email:** farhad.khatibi@kirklees.gov.uk

