

MCS-020 Noise Assessment Report

Heat Pump Sound Assessment



PROJECT DETAILS

Installation Address:	68 Wellhouse Green, Golcar, HUDDERSFIELD, HD7 4ET
Date of Calculation:	2026-08-12
Heat Pump Size:	8kW - 56 dB(A)
Heat Pump Location:	Front of property in view of the main highway

ASSESSMENT POSITION

Position:	Position 1
Reflective Surfaces:	two reflective surfaces
Distance:	5.1 m
Barrier Type:	no barrier
Line of Sight:	full view

RESULT

36.9 dB(A)

PASS - Limit 37 dB(A)

FOREWORD

The previous MCS 020 Standard combined air source heat pumps and wind turbines into one standard. These have now been separated into two new Standards; MCS 020 a) (for air source heat pumps) and MCS 020 b) (for wind turbines).

Compliance with this Standard is mandatory for installers seeking to install air source heat pumps for Permitted Development from the date of implementation 20/09/2025.

NOTES:

This standard makes use of the terms 'must', 'shall' and 'should' when prescribing certain requirements and procedures. In the context of this document:

- the term 'must' identifies a requirement by law at the time of publication;
- the term 'shall' prescribes a requirement or procedure that is intended to be complied with in full and without deviation;
- the term 'should' prescribes a requirement or procedure that is intended to be complied with unless reasonable justification can be given.

This document is only relevant to air source heat pumps. Throughout this document "heat pump" means "air source heat pump".

Issue: 1.0	COPYRIGHT © The MCS Charitable Foundation 2025	MCS 020 a)
Date: 20/03/2025		Page 6 of 20

1 INTRODUCTION, PURPOSE & SCOPE

- 1.1 This document sets out the sound calculation which must be conducted for domestic installations of heat pumps to be 'permitted development'.
- 1.2 It includes a calculation procedure designed to confirm whether the permitted development noise limit of 37 dB $L_{Aeq,5mins}$ (at the assessment positions ignoring the effect of the façade) would be met. The Standard, and the steps and calculations carried out by the installer, can be used by local planning authorities and MCS to verify compliance.
- 1.3 Compliance with MCS 020 a) on its own does not bestow permitted development rights – there are a number of other conditions and limitations which must be complied with for an installation to be permitted development. The full requirements for installations in England can be found at [The Town and Country Planning \(General Permitted Development\) \(England\) Order 2015](#). Requirements in other countries may differ. Installers are advised to contact the local planning authority with any queries.
- 1.4 Contractors shall be under a duty to ensure compliance with MCS 020 a) in relation to any installation carried out as permitted development. The MCS may impose penalties or sanctions if an MCS Contractor fails to ensure compliance with this Standard prior to undertaking an installation. An installation which does not meet this Standard may be subject to enforcement action by the local planning authority.
- 1.5 The heat pump calculation procedure is set out in Table 1 for one heat pump installed at a property and in Table 2 for two heat pumps installed at a property.
- 1.6 Contractors shall complete one table for each assessment position that could potentially be affected by noise from the heat pump. To follow the instructions and complete the table, installers will need to refer to the details in the steps set out after the table.
- 1.7 Installers shall insert their results in the 'result' column for each step of the calculation procedure to show how it has been followed. Contractors shall retain one copy of the completed table for their records and provide another copy to the customer.

2 DEFINITIONS

Term	Definition
Assessment Position	Means a position 1m external to the centre point of any door or window to a habitable room of a neighbouring property as measured perpendicular to the plane of the door or window.
Habitable Room	Means any rooms used or intended to be used for sleeping or living which are not solely used for cooking purposes, but does not include bath or toilet facilities, service rooms, corridors, laundry rooms, hallways or utility rooms.
Neighbouring Property	Means any building used for any of the purposes of Class C of the Town and Country Planning (Use Classes) Order 1987 (as amended) (includes dwellings, houses, hotels, residential institutions and houses in multiple occupation). In instances where the heat pump would be installed on a block of flats, neighbouring property includes flats within the same block of flats (excluding the flat of the “owner(s)” of the heat pump.
Sound Power Level	The logarithmic ratio of a sound power and a reference sound power. The sound power is the total sound energy radiated by a source per unit of time.
Sound Pressure Level	The logarithmic ratio of a sound pressure and a reference sound pressure. The sound pressure is the difference between the instantaneous pressure produced by a sound wave and the barometric pressure at a given point in space.
Decibel (dB)	The logarithmic unit of the ratio of a measured quantity to a reference quantity. Sound power levels and sound pressure levels are stated using the decibel (dB) unit. The reference value used is different for sound power level and sound pressure level.
A-Weighting	A frequency weighting applied to noise levels, which approximates the frequency

	sensitivity of the human ear. An A-weighted sound power level or sound pressure level uses the unit dB(A).
$L_{Aeq,5mins}$	The A-weighted equivalent continuous sound level over a 5-minute period that contains the same sound energy as the actual varying sound over the same time period.
Permitted Development	A national grant of planning permission for certain forms of development. Permitted Development Rights are set out in the Town and Country Planning (General Permitted Development) (England) Order 2015, as amended (Sl. No 596).

3 METHODOLOGY

3.1 TABLES OF ASSESSMENT

Table 1 Determination of sound pressure level at assessment position for one heat pump.

Step	Instructions	Result
1	Date calculation undertaken	
2	Description of assessment position	
3	From manufacturer's data, obtain the A-weighted sound power level of the heat pump.	
4	Determine the directivity 'Q' of the heat pump noise.	
5	Measure the distance from the heat pump to the assessment position in metres.	
6	Determine any barrier corrections between the heat pump and the assessment position.	
7	Calculate the sound pressure level from the heat pump at the assessment position.	
8	Is the calculated sound pressure level at the assessment position equal to or lower than the permitted development noise limit of 37.0 dB(A)?	

Table 2 Determination of sound pressure level at assessment position for two heat pumps.

Step	Instructions	Result Unit 1	Result Unit 2
1	Date calculation undertaken		
2	Description of assessment position		
3	From manufacturer's data, obtain the A-weighted sound power level of the heat pump.		
4	Determine the directivity 'Q' of the heat pump noise.		
5	Measure the distance from the heat pump to the assessment position in metres.		
6	Determine any barrier corrections between the heat pump and the assessment position.		
7a	Calculate the sound pressure level from the heat pump at the assessment position.		
7b	Calculate the total sound pressure level from the heat pump at the assessment position		
8	Is the calculated sound pressure level at the assessment position equal to or lower than the permitted development noise limit of 37.0 dB(A)?		

3.2 STEPS

Step 1

State the date the assessment was carried out. Depending on the time between assessment and installation of the heat pump, it may be necessary to check that nothing has changed which could otherwise impact the assessment. E.g. changes to neighbouring properties, changes to barriers or reflective surfaces.

Step 2

Multiple assessment positions may need to be considered, and an assessment carried out for each, as the closest assessment position is not always the assessment position with the highest sound pressure level. For example, an assessment position could have a larger distance, but clearer line of site. Assessment positions should include neighbouring properties on all sides of the property where the heat pump is to be installed, and include assessment positions at ground floor, first floor, etc. See worked example.

The description shall be detailed enough to allow for identification, including property address and exact location of window/ door opening and floor level. It is recommended that a map,

sketch, photo or other record be attached to these workings for compliance assessments and in case of future queries.

For installations with two heat pumps, it is important to consider all assessment positions for each heat pump. The two heat pumps may have the same assessment positions, but the distances or line of sight may be different. If the two heat pumps are installed further away from each other, they may have different assessment positions and need to be considered as individual heat pumps when determining the overall sound pressure levels. See Step 7 for further details.

Step 3

The A-weighted sound power level of the heat pump should be obtained from manufacturer's data, which can be found on the product fiche, product energy label, or the MCS product database.

The sound power level in "low noise mode" shall not be used.


It is important to use the sound power level of the heat pump, and not the sound pressure level as these are two different quantities. If it is not explicitly clear if the value on a datasheet is a sound power level (e.g. a generic term such as "noise level" is used) then clarity should be sought from the manufacturer before starting the assessment.

The conditions in which the sound power level is determined can be found in the Sound Power Testing for Heat Pumps document found on the MCS website.

Step 4

The sound pressure level increases with the number of reflecting surfaces. A reflective surface is any surface (including the ground, but not vegetation) within 1 m of the heat pump. The reflecting surface shall extend beyond the edge of the heat pump by 1m or more, in two or more directions (i.e. a very low wall next to an heat pump does not count as a reflecting surface).

Use the illustrations below to establish the directivity 'Q' for the installation.



The following examples may be used as a guide:

- $Q2$ = a heat pump with one reflecting surface (i.e. the ground or a single wall if mounted on a wall off the ground)
- $Q4$ = a heat pump with two reflecting surfaces (i.e. ground mounted and against a wall or mounted off ground level against two walls)
- $Q8$ = a heat pump with three reflecting surfaces (i.e. ground mounted and against two walls or mounted off ground level between three walls)

A heat pump with more than three reflective surfaces (for example those within small lightwells) will not meet MCS 020 a).

Step 5

The distance shall be measured to the nearest 0.1m in a straight line between the centre of the heat pump unit and the assessment position.

Step 6

A correction shall be made for attenuation due to barriers between the heat pump and an assessment position. The construction of the barrier and the line of sight between the heat pump and assessment position shall both be taken into account to determine the attenuation of the barrier.

Issue: 1.0	COPYRIGHT © The MCS Charitable Foundation 2025	MCS 020 a)
Date: 20/03/2025		Page 13 of 20

The following definitions of a barrier shall be used for the purposes of this assessment.

- Barrier (Type 1) – a solid brick/masonry wall or a solid fence that is at least 18mm thick. There should be no cracks or gaps in the barrier. The barrier should extend horizontally by 1m or more from either edge of the heat pump.
- Barrier (Type 2) – a solid fence that is less than 18mm thick. There should be no cracks or gaps in the barrier. The barrier should extend horizontally by 1m or more from either edge of the heat pump.
- No barrier – open fences, fences with gaps and cracks, and vegetation do not count as a barrier. Walls or fences in a poor state of repair (e.g. gaps or pieces missing) do not count as a barrier.

The following definitions of line of sight shall be used for the purposes of this assessment.

- No view – If a barrier that completely obscures the vision of an assessment position from the top edge of the heat pump.
- Partial view – If by moving up to 0.25m in any direction from the top edge of the heat pump the assessment position is visible.
- Full view – If the assessment position is visible from the top edge of the heat pump.

The matrix table below shall be used in conjunction with the above definitions to determine the barrier attenuation.

		Line of Sight		
		No view	Partial view	Full view
Barrier Type	Type 1	-10 dB	-5 dB	0 dB
	Type 2	-5 dB	-2.5 dB	0 dB
	No barrier	0 dB	0 dB	0 dB

Step 7

The sound pressure level at the assessment position shall be calculated using the following formula

$$L_p = L_w + 10 \cdot \log\left(\frac{Q}{4 \cdot \pi \cdot r^2}\right) - A_B$$

Where:

L_p = sound pressure level, in dB(A)

L_w = sound power level, in dB(A)

Q = Directivity factor

r = distance from heat pump to assessment position, in metres

A_B = barrier attenuation, in dB(A)

Where two heat pumps are installed and have the same assessment position(s), the sound pressure level at the assessment position for each heat pump shall be calculated and then the total sound pressure level shall be calculated using the logarithmic summation in the following formula, where $L_{p,1}$ and $L_{p,2}$ are the sound pressure levels for each heat pump.

$$L_{p,total} = 10 \cdot \log \left(10^{\frac{L_{p,1}}{10}} + 10^{\frac{L_{p,2}}{10}} \right)$$

The logarithmic summation can be expanded for more than two heat pumps, as given in the following formula.

$$L_{p,total} = 10 \cdot \log \left(10^{\frac{L_{p,1}}{10}} + 10^{\frac{L_{p,2}}{10}} + \dots + 10^{\frac{L_{p,N}}{10}} \right)$$

Step 8


The calculated sound pressure shall be rounded to the nearest 0.1 decimal place. If the calculated sound pressure level at all assessment positions is equal to or lower than 37.0 dB(A) then the heat pump will comply with the Permitted Development noise limit and may be considered permitted development (subject to compliance with other permitted development limitations/conditions and parts of this standard).



If the calculated sound pressure level at all assessment positions is not equal to or lower than 37.0 dB(A) then the heat pump will not comply with the permitted development noise limit and is not permitted development.

It may be possible to make adjustments (e.g. move the heat pump) in order to comply with the Permitted Development noise limit. Further guidance is provided in the Installation Guidance for Mitigating Noise from Air Source Heat Pumps found on the MCS website.

APPENDIX A – WORKED EXAMPLE

Below is a worked example for a standard detached house with multiple potential assessment positions.





Assessment position 1:

Step	Instructions	Result
1	Date Calculation Undertaken	06/11/2024
2	Description of assessment position	16 Willis Close, Chester, CH4 5JH First floor Left rear bedroom (from looking from the front) Window
3	From manufacturer's data, obtain the A-weighted sound power level of the heat pump.	60 dB(A)
4	Determine the directivity 'Q' of the heat pump noise.	2 reflective surfaces – Q4 Against the ground and one wall
5	Measure the distance from the heat pump to the assessment position in metres.	8.0 m
6	Determine any barrier corrections between the heat pump and the assessment position.	Brick wall Partial line of sight
7	Calculate the sound pressure level from the heat pump at the assessment position.	32.0 dB(A)
8	Is the calculated sound pressure level at the assessment position equal to or lower than the permitted development noise limit of 37.0 dB(A)?	Yes

$$60 + 10.\log\left(\frac{4}{4 * \pi * 8^2}\right) - 5 = 31.96$$

Assessment position 2:

Step	Instructions	Result
1	Date Calculation Undertaken	06/11/2024
2	Description of assessment position	16 Willis Close, Chester, CH4 5JH Ground floor Left rear sitting room (from looking from the front) French windows
3	From manufacturer's data, obtain the A-weighted sound power level of the heat pump.	60 dB(A)
4	Determine the directivity 'Q' of the heat pump noise.	2 reflective surfaces – Q4 Against the ground and one wall
5	Measure the distance from the heat pump to the assessment position in metres.	5.0 m
6	Determine any barrier corrections between the heat pump and the assessment position.	Brick wall No line of sight
7	Calculate the sound pressure level from the heat pump at the assessment position.	31.0 dB(A)
8	Is the calculated sound pressure level at the assessment position equal to or lower than the permitted development noise limit of 37.0 dB(A)?	Yes

$$60 + 10 \cdot \log\left(\frac{4}{4 * \pi * 5^2}\right) - 10 = 31.04$$

Assessment position 3:

Step	Instructions	Result
1	Date Calculation Undertaken	06/11/2024
2	Description of assessment position	8 Grange Road, Chester, CH4 5PY First floor Right rear bedroom (from looking from the front) Window
3	From manufacturer's data, obtain the A-weighted sound power level of the heat pump.	60 dB(A)
4	Determine the directivity 'Q' of the heat pump noise.	2 reflective surfaces – Q4 Against the ground and one wall
5	Measure the distance from the heat pump to the assessment position in metres.	15.0 m
6	Determine any barrier corrections between the heat pump and the assessment position.	Slatted fence Full line of sight
7	Calculate the sound pressure level from the heat pump at the assessment position.	31.5 dB(A)
8	Is the calculated sound pressure level at the assessment position equal to or lower than the permitted development noise limit of 37.0 dB(A)?	Yes

$$60 + 10 \cdot \log \left(\frac{4}{4 * \pi * 15^2} \right) = 31.50$$