

**Consultation Response from KC,
Ecology Unit****2026/92635 Salamander Fabrications, Commercial Mills, Canal Side, Slaithwaite,
Huddersfield, HD7 5HB****Discharge of details reserved by conditions 3 (materials), 4 (construction vehicles), 6 (lighting), 7 (CEMP), 8 (Phase I Desk Study Report) and 13 (noise assessment) on previous permission 2026/91443 for erection of extension and alterations including associated works****Date Responded: 07/10/2026****Responding Officer: Z. Hanshaw****Responding Ref: 2610/15**

I have reviewed the information submitted with this application for the discharge of condition 6. This is as follows:

6. No works are to commence unless a detailed lighting scheme, developed in accordance with established guidance (e.g. Bat Conservation Trust and Institute of Lighting Professionals (2023) Bats and Artificial Lighting at Night), has been drafted and agreed with the council. The Sensitive Lighting Strategy will demonstrate that the proposed lighting will not impact upon ecological networks and/or sensitive features. Thereafter the agreed lighting scheme shall be implemented, subject to any variations approved in writing by the Planning Authority. All external lighting shall be installed strictly in accordance with the specifications and locations set out within the Lighting Strategy.

The Proposed Site Plan (Colne Valley Design, May 2026) shows that only a single light will be installed this will be shielded from the River Colne by the buildings onsite. The Supporting Statement states that this light will be warm white at 2700K and can be angled down to ensure that there is no upwards light spill. I am therefore satisfied that there will be no illumination of the nearby River or Woodland. This condition can therefore be discharged.